



# Professional Laboratory Services

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

## ANALYSIS REPORT

Reported: 03/02/2022  
Received: 02/16/2022  
Sampled By: Brent Paul  
Work Order: 2048016

**C** Lake Oswego School District  
**L** Attn: Brent Paul  
**I** 4200 Douglas Way  
**E** Lake Oswego OR, 97034-3439  
**N** Phone: (503) 780-7215  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: LGE - Lake Grove Elementary

### Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2048016-01</b>	<b>Sample Name:</b> #1 Bottle LGE <b>Sampled:</b> 2/15/22 7:00						<b>Matrix:</b> Water
+Copper	1055	SM3111B	ND	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-02</b>	<b>Sample Name:</b> #2 Health LGE <b>Sampled:</b> 2/15/22 7:00						<b>Matrix:</b> Water
+Copper	1055	SM3111B	50	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-03</b>	<b>Sample Name:</b> #3 Rm 20 LGE <b>Sampled:</b> 2/15/22 7:00						<b>Matrix:</b> Water
+Copper	1055	SM3111B	655	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	18	ppb	1	15 ppb	02/24/22 16:07 MCLE
<b>2048016-04</b>	<b>Sample Name:</b> #4 Rm 22 LGE <b>Sampled:</b> 2/15/22 7:00						<b>Matrix:</b> Water
+Copper	1055	SM3111B	109	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-05</b>	<b>Sample Name:</b> #5 Rm 25 LGE <b>Sampled:</b> 2/15/22 7:00						<b>Matrix:</b> Water
+Copper	1055	SM3111B	ND	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-06</b>	<b>Sample Name:</b> #6 Rm 23 LGE <b>Sampled:</b> 2/15/22 7:00						<b>Matrix:</b> Water
+Copper	1055	SM3111B	178	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/24/22 16:07
<b>2048016-07</b>	<b>Sample Name:</b> #7 Rm 21 LGE <b>Sampled:</b> 2/15/22 7:00						<b>Matrix:</b> Water
+Copper	1055	SM3111B	64	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/24/22 16:07



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 03/02/2022  
Received: 02/16/2022  
Sampled By: Brent Paul  
Work Order: 2048016

**C  
L  
I  
E  
N  
T**  
**Lake Oswego School District**  
Attn: Brent Paul  
4200 Douglas Way  
Lake Oswego OR, 97034-3439  
Phone: (503) 780-7215

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: LGE - Lake Grove Elementary

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2048016-08</b>	<b>Sample Name:</b> #8 Rm 19 LGE <b>Sampled:</b> 2/15/22 7:00						<b>Matrix:</b> Water
+Copper	1055	SM3111B	ND	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	12	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-09</b>	<b>Sample Name:</b> #9 Rm 15 LGE <b>Sampled:</b> 2/15/22 7:00						<b>Matrix:</b> Water
+Copper	1055	SM3111B	ND	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-10</b>	<b>Sample Name:</b> #10 Lib LGE <b>Sampled:</b> 2/15/22 7:00						<b>Matrix:</b> Water
+Copper	1055	SM3111B	ND	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-11</b>	<b>Sample Name:</b> #11 Rm 13 LGE <b>Sampled:</b> 2/15/22 7:00						<b>Matrix:</b> Water
+Copper	1055	SM3111B	58	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-12</b>	<b>Sample Name:</b> #12 Bottle Hall LGE <b>Sampled:</b> 2/15/22 7:00						<b>Matrix:</b> Water
+Copper	1055	SM3111B	ND	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-13</b>	<b>Sample Name:</b> #13 Music LGE <b>Sampled:</b> 2/15/22 7:00						<b>Matrix:</b> Water
+Copper	1055	SM3111B	318	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	6	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-14</b>	<b>Sample Name:</b> #14 Kitchen LGE <b>Sampled:</b> 2/15/22 7:00						<b>Matrix:</b> Water
+Copper	1055	SM3111B	ND	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/22/22 15:55



# Professional Laboratory Services

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

## ANALYSIS REPORT

Reported: 03/02/2022  
Received: 02/16/2022  
Sampled By: Brent Paul  
Work Order: 2048016

**C** Lake Oswego School District  
**L** Attn: Brent Paul  
**I** 4200 Douglas Way  
**E** Lake Oswego OR, 97034-3439  
**N** Phone: (503) 780-7215  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: LGE - Lake Grove Elementary

### Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2048016-15</b> <b>Sample Name:</b> #15 Staff LGE <b>Matrix:</b> Water <b>Sampled:</b> 2/15/22 7:00							
+Copper	1055	SM3111B	ND	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-16</b> <b>Sample Name:</b> #16 Rm. 11 LGE <b>Matrix:</b> Water <b>Sampled:</b> 2/15/22 7:00							
+Copper	1055	SM3111B	ND	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-17</b> <b>Sample Name:</b> #17 Rm. 9 LGE <b>Matrix:</b> Water <b>Sampled:</b> 2/15/22 7:00							
+Copper	1055	SM3111B	ND	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-18</b> <b>Sample Name:</b> #18 Rm. 7 LGE <b>Matrix:</b> Water <b>Sampled:</b> 2/15/22 7:00							
+Copper	1055	SM3111B	206	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/24/22 16:07
<b>2048016-19</b> <b>Sample Name:</b> #19 Rm. 5 LGE <b>Matrix:</b> Water <b>Sampled:</b> 2/15/22 7:00							
+Copper	1055	SM3111B	357	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-20</b> <b>Sample Name:</b> #20 Rm. 4 LGE <b>Matrix:</b> Water <b>Sampled:</b> 2/15/22 7:00							
+Copper	1055	SM3111B	ND	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-21</b> <b>Sample Name:</b> #21 Rm. 3 LGE <b>Matrix:</b> Water <b>Sampled:</b> 2/15/22 7:00							
+Copper	1055	SM3111B	62	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	9	ppb	1	15 ppb	02/22/22 15:55



# Professional Laboratory Services

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

## ANALYSIS REPORT

Reported: 03/02/2022  
Received: 02/16/2022  
Sampled By: Brent Paul  
Work Order: 2048016

**C** Lake Oswego School District  
**L** Attn: Brent Paul  
**I** 4200 Douglas Way  
**E** Lake Oswego OR, 97034-3439  
**N** Phone: (503) 780-7215  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: LGE - Lake Grove Elementary

### Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2048016-22</b> <b>Sample Name:</b> #22 Rm. 2 LGE <b>Matrix:</b> Water <b>Sampled:</b> 2/15/22 7:00							
+Copper	1055	SM3111B	<b>1370</b>	ppb	50	1300 ppb	03/01/22 11:25 <b>MCLE</b>
+Lead	1030	EPA 200.9	<b>127</b>	ppb	10	15 ppb	02/24/22 16:07 <b>MCLE</b>
<b>2048016-23</b> <b>Sample Name:</b> #23 Rm. 1 LGE <b>Matrix:</b> Water <b>Sampled:</b> 2/15/22 7:00							
+Copper	1055	SM3111B	<b>82</b>	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-24</b> <b>Sample Name:</b> #24 Rm. 6 LGE <b>Matrix:</b> Water <b>Sampled:</b> 2/15/22 7:00							
+Copper	1055	SM3111B	<b>87</b>	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/24/22 16:07
<b>2048016-25</b> <b>Sample Name:</b> #25 Rm. 8 LGE <b>Matrix:</b> Water <b>Sampled:</b> 2/15/22 7:00							
+Copper	1055	SM3111B	ND	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/24/22 16:07
<b>2048016-26</b> <b>Sample Name:</b> #26 Rm. 10 LGE <b>Matrix:</b> Water <b>Sampled:</b> 2/15/22 7:00							
+Copper	1055	SM3111B	<b>82</b>	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-27</b> <b>Sample Name:</b> #27 Rm. 12 LGE <b>Matrix:</b> Water <b>Sampled:</b> 2/15/22 7:00							
+Copper	1055	SM3111B	<b>55</b>	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-28</b> <b>Sample Name:</b> #28 Rm. 14B LGE <b>Matrix:</b> Water <b>Sampled:</b> 2/15/22 7:00							
+Copper	1055	SM3111B	ND	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	7	ppb	1	15 ppb	02/22/22 15:55



# Professional Laboratory Services

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

## ANALYSIS REPORT

Reported: 03/02/2022  
Received: 02/16/2022  
Sampled By: Brent Paul  
Work Order: 2048016

**C** Lake Oswego School District  
**L** Attn: Brent Paul  
**I** 4200 Douglas Way  
**E** Lake Oswego OR, 97034-3439  
**N** Phone: (503) 780-7215  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: LGE - Lake Grove Elementary

### Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2048016-29</b>	<b>Sample Name:</b> #29 Rm. 16 LGE <b>Sampled:</b> 2/15/22 7:00						<b>Matrix:</b> Water
+Copper	1055	SM3111B	ND	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-30</b>	<b>Sample Name:</b> #30 Rm. 17 LGE <b>Sampled:</b> 2/15/22 7:00						<b>Matrix:</b> Water
+Copper	1055	SM3111B	ND	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	5	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-31</b>	<b>Sample Name:</b> #31 PTA LGE <b>Sampled:</b> 2/15/22 7:00						<b>Matrix:</b> Water
+Copper	1055	SM3111B	<b>76</b>	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	15	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-32</b>	<b>Sample Name:</b> #32 Gym Btl. LGE <b>Sampled:</b> 2/15/22 7:00						<b>Matrix:</b> Water
+Copper	1055	SM3111B	<b>83</b>	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-33</b>	<b>Sample Name:</b> #33 Hall Btl. LGE <b>Sampled:</b> 2/15/22 7:00						<b>Matrix:</b> Water
+Copper	1055	SM3111B	<b>88</b>	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/22/22 15:55
<b>2048016-34</b>	<b>Sample Name:</b> #34 Rm. 18 LGE <b>Sampled:</b> 2/15/22 7:00						<b>Matrix:</b> Water
+Copper	1055	SM3111B	ND	ppb	50	1300 ppb	03/01/22 11:25
+Lead	1030	EPA 200.9	5	ppb	1	15 ppb	02/22/22 15:55

**MCLE** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 03/02/2022  
Received: 02/16/2022  
Sampled By: Brent Paul  
Work Order: 2048016

**C** Lake Oswego School District  
**L** Attn: Brent Paul  
**I** 4200 Douglas Way  
**E** Lake Oswego OR, 97034-3439  
**N** Phone: (503) 780-7215  
**T**

**Project:**

Project # : N/A  
Sample Type :

Sampling Location: LGE - Lake Grove Elementary

---

**Lab Number**

**Note:** Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: \_\_\_\_\_

A handwritten signature in black ink, appearing to read 'Adriana', is written over a horizontal line. Below the signature, the name 'Adriana Gonzalez-Gray' and the title 'Laboratory Director' are printed in a small, black, sans-serif font.

Adriana Gonzalez-Gray  
Laboratory Director