



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/07/2022
Received: 02/18/2022
Sampled By: Brent Paul
Work Order: 2053007

C Lake Oswego School District
L Attn: Brent Paul
I 4200 Douglas Way
E Lake Oswego OR, 97034-3439
N Phone: (503) 780-7215
T

Project:
Project # : N/A
Sample Type :

Sampling Location: RGE - River Grove Elementary

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2053007-01	Sample Name: #30 D6B RGE Sampled: 2/17/22 7:00					Matrix: Water	
+Copper	1055	SM3111B	168	ppb	50	1300 ppb	03/03/22 13:05
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/28/22 16:05
2053007-02	Sample Name: #31 D5 RGE Sampled: 2/17/22 7:00					Matrix: Water	
+Copper	1055	SM3111B	230	ppb	50	1300 ppb	03/03/22 13:05
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/28/22 16:05
2053007-03	Sample Name: #29 D6A RGE Sampled: 2/17/22 7:00					Matrix: Water	
+Copper	1055	SM3111B	222	ppb	50	1300 ppb	03/03/22 13:05
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/28/22 16:05
2053007-04	Sample Name: #32 D4 RGE Sampled: 2/17/22 7:00					Matrix: Water	
+Copper	1055	SM3111B	185	ppb	50	1300 ppb	03/03/22 13:05
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/28/22 16:05
2053007-05	Sample Name: #33 D3A RGE Sampled: 2/17/22 7:00					Matrix: Water	
+Copper	1055	SM3111B	135	ppb	50	1300 ppb	03/03/22 13:05
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/28/22 16:05
2053007-06	Sample Name: #34 D3B RGE Sampled: 2/17/22 7:00					Matrix: Water	
+Copper	1055	SM3111B	173	ppb	50	1300 ppb	03/03/22 13:05
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/28/22 16:05
2053007-07	Sample Name: #35 D2A RGE Sampled: 2/17/22 7:00					Matrix: Water	
+Copper	1055	SM3111B	172	ppb	50	1300 ppb	03/03/22 13:05
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/28/22 16:05



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/07/2022
Received: 02/18/2022
Sampled By: Brent Paul
Work Order: 2053007

C Lake Oswego School District
L Attn: Brent Paul
I 4200 Douglas Way
E Lake Oswego OR, 97034-3439
N Phone: (503) 780-7215
T

Project:
Project # : N/A
Sample Type :

Sampling Location: RGE - River Grove Elementary

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2053007-08	Sample Name: #36 D2B RGE Sampled: 2/17/22 7:00					Matrix: Water	
†Copper	1055	SM3111B	178	ppb	50	1300 ppb	03/03/22 13:05
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/28/22 16:05
2053007-09	Sample Name: #37 D1A RGE Sampled: 2/17/22 7:00					Matrix: Water	
†Copper	1055	SM3111B	147	ppb	50	1300 ppb	03/03/22 13:05
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/28/22 16:05
2053007-10	Sample Name: #38 D1B RGE Sampled: 2/17/22 7:00					Matrix: Water	
†Copper	1055	SM3111B	213	ppb	50	1300 ppb	03/03/22 13:05
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/28/22 16:05
2053007-11	Sample Name: #39 STEM L RGE Sampled: 2/17/22 7:00					Matrix: Water	
†Copper	1055	SM3111B	150	ppb	50	1300 ppb	03/03/22 13:05
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/28/22 16:05
2053007-12	Sample Name: #40 STEM B RGE Sampled: 2/17/22 7:00					Matrix: Water	
†Copper	1055	SM3111B	100	ppb	50	1300 ppb	03/03/22 13:05
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/28/22 16:05
2053007-13	Sample Name: #41 STEM A RGE Sampled: 2/17/22 7:00					Matrix: Water	
†Copper	1055	SM3111B	113	ppb	50	1300 ppb	03/03/22 13:05
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/28/22 16:05

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/07/2022
Received: 02/18/2022
Sampled By: Brent Paul
Work Order: 2053007

C Lake Oswego School District
L Attn: Brent Paul
I 4200 Douglas Way
E Lake Oswego OR, 97034-3439
N Phone: (503) 780-7215
T

Project:

Project # : N/A
Sample Type :

Sampling Location: RGE - River Grove Elementary

Lab Number

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____

A handwritten signature in black ink, appearing to read 'Adriana', is written over a horizontal line. Below the line, the name 'Adriana Gonzalez-Gray' and the title 'Laboratory Director' are printed in a small, black, sans-serif font.

Adriana Gonzalez-Gray
Laboratory Director